



# Certificate of Compliance

**Certificate:** 70089255

**Master Contract:** 264700

**Project:** 70089255

**Date Issued:** 2016-09-01

**Issued to:** **Energo Group Canada Inc.**  
**2530 Hochwald Avenue SW**  
**Calgary, Alberta T3E 7H5**  
**CANADA**  
**Attention: Dragan Lemez**

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** *Douglas Bramwell*  
Douglas Bramwell

## **PRODUCTS**

CLASS 5411 04 – TRANSFORMERS – MISCELLANEOUS

High voltage instrument transformers, potential type, Series VTOP followed by suffixes, primary rated up to 27.6 kV; secondary rated 120 Vac, 250 VA @ Class 3%, Insulation Class F.

### Notes:

1. These transformers are provided without an enclosure. Final acceptance of installation to be determined by the authorities having jurisdiction.
2. The evaluation of these instrument transformers cover electrical shock hazards only. Performance was not evaluated.

## **APPLICABLE REQUIREMENTS**

C22.2 No. 47-13 – Air Cooled Transformers (Dry Type)



## *Supplement to Certificate of Compliance*

**Certificate:** 70089255

**Master Contract:** 264700

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
70089255	2016-09-01	High voltage instrument transformers, potential type, Series VTOP.